

## 10. Dimensions

- a. Thickness. The total thickness of the finished slab shall be not less than five (5) inches.
- b. Length. The length shall be not less than one hundred and ten (110) feet. (See Note.)

Note: For official tournament play, the length of the slab shall be not less than 120 feet.

- c. Width. One court. The width shall be not less than sixty (60) feet.

## 11. Placing Reinforcement

- a. Metal reinforcement, shall be thoroughly cleaned of mill and rust scale and of coatings that will destroy or reduce the bond. The effective weight per 100 square feet shall be not less than 80 pounds. Reinforcement shall be accurately placed within the slab, two (2) inches from the top surface of the court.

## 12. Expansion Joints

- a. Expansion joints shall be provided at the net line and at the longitudinal center line between abutting courts.

- b. Expansion joints at the net line shall be at least one-half ( $1/2$ ) inch wide and between courts shall be at least one (1) inch wide. All expansion joints shall extend the full depth of the slab and shall be filled with prepared felt or other suitable material trimmed level with the surface of the court.

Note: Adjacent courts may be divided by a strip of turf one (1) foot or more in width.

- c. Reinforcing shall not be carried continuously across expansion joints.

- d. All joints shall be finished with one-quarter ( $1/4$ ) inch edging tool.

## 13. Construction Joints

- a. When approved by the engineer, construction joints may be made to conform to the playing lines of the court or to come at any location in the concrete slab outside the field of play.

- b. Reinforcing shall be carried continuously over all construction joints.