

STATE OF KANSAS

STATE BOARD OF HEALTH

Water and Sewage Laboratory
Cassandra Ritter, Bacteriologist
Robert H. Hess, Chemist

Sanitary Engineering Section
Paul D. Haney, Chemical Engineer
Wendell C. Wyatt, Asst. Engineer
P. C. Sharp, Asst. Engineer

F. P. HELM, M.D., Topeka
Secretary and Executive Officer

Oil Field Waste Disposal Section
Ogden S. Jones, Geologist
Richard G. Prough, Asst. Geol.

Industrial Hygiene Section
Charles C. Dills, Engineer
Arthur L. Nichols, Hygienist

DIVISION OF SANITATION
Marvin Hall, University of Kansas

Earnest Boyce, Engineer and Director
Nelle Schneider, Asst. Director

LAWRENCE, KANSAS

November 1, 1939

Athletic Department
Kansas University
Campus

Gentlemen:

We are reporting herewith the bacteriological analysis of the two samples from the swimming pool--one marked "east end" and one marked "west end".

Both of these samples must be reported as in bad condition, in that organisms of the coliform group were found present in all of the five 10 c.c. portions and in all of the three 1 c.c. portions examined.

We would suggest that it may be desirable to overhaul the water purification installation, including the filter, and to provide for a reasonable chlorination. There have been a great many complaints during the past years with regard to overchlorination of the pool. We believe it is possible to maintain the pool free of coli and at the same time not maintain such a high chlorine residual that the water is objectionable to bathers.

Very truly yours,

DIVISION OF SANITATION



Earnest Boyce
Engineer and Director

EB:ME