

**SWIMMING POOL
OPERATION SCHEDULE**

- MONDAY**
- 7:30 A.M. - Check pool temperature (78°)
Check pool level (one brick below blue line)
Backwash filter until water is clear
Start pump
Start heat if pool temp. is below 78°
Adjust level of pool (drain or fill to proper depth)
Start chlorinator
Unlock men's door to pool
Turn on pool lights and ventilator
Flush ramp and screen pool water
 - 9:20 A.M. - Flush ramp and screen pool water
 - 10:20 A.M. - " " " " " "
 - 11:20 A.M. - " " " " " "
Lock men's door to pool
 - 12:20 P.M. - Flush ramp and screen pool water
Check chlorine (if above .5ppm., shut off chlorinator)
Check pool temp. (if above 80° shut off heater)
 - 3:20 P.M. - Flush ramp and screen pool water
 - 4:20 P.M. - " " " " " "
 - 5:20 P.M. - Flush ramp and screen pool water
Tidy up ramp
Take sample of pool water
Shut off lights and ventilator
Lock men's door to pool
Shut off chlorinator
Shut off heater
Shut off pump
Deliver pool water sample to lab in Marvin Hall
- TUESDAY**
- 6:30 A.M. - Same as Monday 7:30 A.M.
 - 8:20 A.M. - Flush ramp and screen pool water.
 - 9:20 A.M. - " " " " " "
 - 10:20 A.M. - " " " " " "
 - 11:20 A.M. - " " " " " "
Lock men's door to pool
 - 12:20 P.M. - Same as Monday 12:20 P.M.
 - 3:20 P.M. - Flush ramp and screen pool water
 - 4:20 P.M. - " " " " " "
 - 5:20 P.M. - Same as Monday 5:20 P.M. except no water sample.
- WEDNESDAY** - Same as Monday except no water sample
- THURSDAY** - Same as Tuesday and take water sample at 5:30 P.M.
- FRIDAY** - Same as Tuesday