

# E. W. BACHARACH & CO.

FILTER PLANT EQUIPMENT  
GRAVITY AND PRESSURE FILTERS  
WATER SOFTENING PLANTS  
CHEMICAL TREATING PLANTS  
SEWAGE DISPOSAL EQUIPMENT



*Water Purification Plants*

RIALTO BLDG · KANSAS CITY · MISSOURI

August 13, 1943

Dr. Forrest C. Allen  
Director of Physical Education  
Varsity Basket Ball Coach  
University of Kansas  
Lawrence, Kansas

Dear Sir:

Your letter of the 12th received, regarding gauges.

The vacuum and pressure gauge should be installed on the suction side of the pump, that is, in the pipe nipple between the pump suction and lint catcher. We understand that a tap has been provided to accommodate the gauge.

Very truly yours,

E. W. BACHARACH & COMPANY

AWL:EP