

REPORT OF WATER ANALYSIS—CITY OF Lawrence

Laboratory No.	405490		
Source	Surf. W. (inlet) end .60	Bottom E. (outlet) .60 end	
Collected by	Physical Ed. Department		
Date of collection	10-29-40		
Date received	10-29-40		
Analysis completed	10-31-40		
BACTERIAL EXAMINATION *			
Bacteria per cc. on Agar, at 37°—24 hrs.	600	800	
Presumptive Tests for Coli-Aerogenes Group Results of Fermentation Tests:	-	-	
in 5 10 cc. tubes	5-	5-	
in 3 1 cc. tubes	3-	3-	
in 3 .1 cc. tubes			
in 3 .01 cc. tubes			
in 3 .001 cc. tubes			
Confirmatory Tests for Coli-Aerogenes Group			
CHEMICAL ANALYSIS Results in parts per million.			
Color			
Odor			
Turbidity	under 1	under 1	
5 day B. O. D.			
Nitrogen as Nitrites			
Nitrogen as Nitrates			
Solids, total			
Special			
Special			
MINERAL ANALYSIS			
HCO ₃ (Bicarbonate)	52	40	
CO ₃ (Carbonate)			
OH (Hydroxide)			
Cl (Chlorides)		66	
Fe (Iron)			
Special			
.....			
.....			
.....			
.....			

* Gas in the fermentation tubes and confirmatory test indicate the presence of bacterial organisms of the Coli-Aerogenes group. These organisms inhabit the intestinal tract of warm-blooded animals, hence their presence in water shows sewage contamination or pollution from surface drainage. Plus sign, gas present. Minus sign, gas absent.

One part per million is equivalent to 1 pound of substance per million pounds of water. One gallon weighs 8.33 pounds. 17.1 parts per million=1 grain per gallon.