STATE OF KANSAS

STATE BOARD OF HEALTH

F. P. HELM, M.D., Topeka
Secretary and Executive Officer

Water and Sewage Laboratory
Cassandra Ritter, Bacteriologist
Robert H. Hess, Chemist

Sanitary Engineering Section
Paul D. Haney, Chemical Engineer
Wendell C. Wyatt, Asst. Engineer
P. C. Sharp, Asst. Engineer

Oil Field Waste Disposal Section
Ogden S. Jones, Geologist
Richard G. Prough, Asst. Geol.

Industrial Hygiene Section
Charles C. Dills, Engineer
Arthur L. Nichols, Hygienist

DIVISION OF SANITATION
Marvin Hall, University of Kansas

Earnest Boyce, Engineer and Director
Nelle Schneider, Asst. Director

LAWRENCE, KANSAS

October 31, 1940

Mr. Jim Raport
107 Robinson Gymnasium
Kansas University
Lawrence, Kansas

Dear Mr. Raport:

The rating of these samples is good from a bacteriological standpoint.

In our swimming pool ratings, samples which show a bacterial count of not over 200 bacteria per cubic centimeter are given a rating of excellent. The good rating is used for samples showing bacterial count of over 200. Samples showing the presence of coliform organisms are given ratings of fair and unsatisfactory. Usually samples showing a residual chlorine content of .6 parts per million, as these samples did, have a bacterial count of less than 200.

If you wish to have regular analyses made will you please come to the laboratory for sterilized bottles and we can make arrangements for additional analyses.

Very truly yours,

DIVISION OF SANITATION

Cassandra Ritter.

CR:R